

MANUFACTURER: Americlad, LLC 21925 Industrial Blvd. Rogers, MN 55374

Telephone: (866) 260-4047

Fax: (763) 255-3399

Email: info@americlad.com

Americlad AC-4300 Formed Flush Glaze Infill Panel System

# SECTION 07 42 00 / 08 44 00 FLUSH GLAZE INSULATED METAL INFILL PANEL

#### PART 1 – GENERAL

#### 1.1 RELATED DOCUMENTS

A. The drawings and provisions of the General Conditions, and the sections included under Division 1 specification sections, apply to this section

#### 1.2 SUMMARY

A. This section includes insulated metal infill panels that are used as the exterior and interior cladding

#### 1.3 PERFORMANCE REQUIREMENTS

- A. Design panel system to accommodate tolerance of plus or minus 1/16" in overall panel thickness and plus or minus 1/8" in any direction
- B. Structural Performance: provide exterior and interior wall cladding assemblies to meet effects of load and stresses from wind loads

## 1.4 SUBMITTALS

- A. Product Data: Manufacturer's product literature
- B. Manufacturer's standard color charts
- C. Finish Samples: submit color samples for final approval
- D. Shop Drawings: submit shop drawings showing plans, sections and details



# **QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Minimum of five years' experience in manufacturing of metal wall panel products
- B. Installer Qualifications: Acceptable to manufacturer

# 1.5 DELIVERY, STORAGE AND HANDLING

- A. Delivery: deliver metal panels in manufacturer's crates packed for long haul transit
- B. Storage: store materials in a dry and safe area
- C. Handling: handle materials to avoid any damage to materials and finishes

#### 1.6 WARRANTY

A. The contractor must warrant the materials to be free of defects in accordance with the general conditions. Finish warranty shall be extended by paint manufacturer's standard warranty

#### **PART 2 - PRODUCTS**

## 2.1 MANUFACTURER

- A. Americlad LLC, 21925 Industrial Boulevard, Rogers, Minnesota 55374, Telephone: (866) 260-4047, www.americlad.com
  - 1. AC-4300 Formed Flush Glaze Infill Panel System
- B. Approved equal submitted for approval 10 days prior to bid

# 2.2 MATERIALS

٩.	A. Aluminum Sheet: ASTM B209, Aluminum	Association specification
	1. 3003-H14/3105-H14/5052-H32 for painted finishes	
	2. 5005-H34 for anodized finish	
В.	3. Thickness: Varies	
С.	C. Exterior Skin shall be	(Specify). Color shall be
	(Specify)	
D.	Stabilizer sheet under both faces shall be 1/8" thick	
Ε.	Core shall be 2.5# density Expanded Polystyrene Foam or	
	Isocyanurate Foam (Specify)	
F.	F. Interior Skin shall be(S	pecify). Color shall be
	(Specify)	

#### 2.3 FABRICATION

- A. Tolerances
  - 1. Width and Length to be plus or minus 1/8"
  - 2. Thickness to be plus or minus 1/16"
- B. Panel surfaces shall be free from defects, scratches or marks caused during fabrication

C.



## 2.4 ACCESSORIES

A. Installer shall supply all materials required for installation

#### 2.5 FINISHES

#### A. Coil Painted:

- 1. Coating shall be a Coil Applied Fluorocarbon Resin Utilizing a 70% Kynar 500/Hylar 5000 resin
- 2. Color as selected by owner from Americlad's standard colors Chart
- 3. Material to be painted in accordance with either AAMA 621-02

### B. Paint:

- 1. Coating shall be a Spray Applied Fluorocarbon Resin Utilizing a 70% Kynar 500/Hylar 5000 resin
- 2. Color as selected by owner from paint manufacturer's standard colors or Custom color as specified
- 3. Material to be painted in accordance with either AAMA specification 2605 or 2604

#### C. Anodized:

- 1. Clear Anodic Finish: mechanical finish, nonspecular as fabricated. Coating to have an anodic coating
- 2. Color Anodic Finish: mechanical finish, nonspecular as fabricated. Color to be determined by Owner.

#### **PART 3 - EXECUTION**

# 3.1 PREPARATION

A. Coordinate drawings, diagrams, and instructions for installation

#### 3.2 INSTALLATION

- A. Setting blocks should be at quarter points of each panel and in a width equal or larger than the panel thickness
- B. Panels to be sealed with Class A grade sealants
- C. Weep holes for frame assemblies to accommodate proper draining
- D. The entire panel perimeter should be engaged into the framing system to allow a minimum of 1/2"
- E. A minimum of 1/4" of clearance must be maintained around the panel perimeter



# 3.3 CLEANING AND PROTECTION

- A. Clean exposed surfaces after installation per manufacturer's recommendation
- B. Touch up minor abrasions in finish with touch up paint supplied by finish applicator

**END OF SECTION**